
REV	D
А	10/
В	11



**SPECIFICATIONS:** 

**VOLTAGE RATING:** 600V

**AMP RATING:** 30 AMPERES


**INTERRUPT RATING:** 200kA

WIRE RANGE: #8-14 AWG STRANDED Cu ONLY UL CLASS B & CLASS C WIRE #10-14 AWG SOLID Cu ONLY

35.0 [1.38]

SUGGESTED TORQUE: 2 N-m [17.7 IN-LB]

APPROVALS: UL LISTED (FILE NO. E14721) CSA CERTIFIED (FILE NO. LR7316)



/ DATE	DESCRIPTION		
10/13/22 11/8/22	525748GCP - RELEASE MRY 525898ECP/D - CHANGE TOLERANCE & WIRE RANGE MRY		
1			
NO COMPONE	-	U/M	
	BILL OF MATERIAL		
<\$>	CRITICAL CHARACTERISTIC FOR PART SAFETY/COMPLIANCE		
•	DENOTES CRITICAL CHARACTERISTICS.		
СРК	DENOTES CPK DIMENSIONS, -MINIMUM CPK VALUE		
(ST) DENOTES A CHARACTERISTIC THAT PROVIDES AN INDICATION OF PROCESS PERFORMANCE. PROCEDURE FOR MEASUREMENT AND TRACKING TO BE DEFINED IN LITTELFUSE INSPECTION INSTRUCTIONS.			
СР	DENOTES CP DIMENSIONS, -MINIMUM CP VALUE MUST BE WITHIN THE DIMENSIONAL LIMITATIONS SHOWN ON DRAWING AND INITIALLY LOCATED TO ALLOW FOR MAXIMUM TOOL LIFE.	B	
MATL SPEC	FINISH		
orw JMOLER	DATE SCALE FINISH GOOD 10/4/2022 NTS GRAM	WT MS/PIECE	
UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN MILLIMETERS, DIMENSIONS IN BRACKETS [ ] ARE INCHES DIMENSIONING AND DO NOT INCLUDE PLATING. TOLERANCING TO BE INTERPRETED IN ACCORDANCE WITH ANSI Y14.5M-1994			
3RD ANGLE PROJECTION			
LPSC001 OUTLINE			
CHICAGO, ILLINOIS 60631 REVISION DRWG NO. SHEET 1 OF 1			

REVISION