

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50405573

Blatt *Sheet*
0001

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
S.L.	01-KSH-50139026 001	21.05.2018 (day/mo/yr)

Genehmigungsinhaber *License Holder*
Littelfuse Inc.
O'Hare Plaza II Ste 500
8755 W. Higgins Rd.
Chicago, IL 60631
USA

Fertigungsstätte *Manufacturing Plant*
Suzhou Littelfuse OVS Ltd
6 Xinghai Street
Suzhou Industrial Park
Suzhou, Jiangsu 215021
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60127-1:2006+A1+A2
EN 60127-7:2016

Zertifiziertes Produkt (Geräteidentifikation) *Certified Product (Product Identification)*

**Lizenzentgelte - Einheit
*License Fee - Unit***

Fuse Link (Miniature Fuse-link)

Type Designation : 325 SP series
(Littelfuse)

5

Rated Voltage : 1) AC 250V
2) AC 125V
3) DC 125V

Rated Current : 12A; 15A

T/I Characteristic : t1=5s; t2=60s; t8=1s

Rated Breaking Capacity: 1) 400A
2) 10kA
3) 600A

5

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Jie Zhang