


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Surge Protective Device
Name and address of the applicant	DongGuan Littelfuse Electronics Co., Ltd Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province, China
Name and address of the manufacturer	DongGuan Littelfuse Electronics Co., Ltd Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province, China
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 DongGuan Littelfuse Electronics Co., Ltd Nanfang East Road, Beice, Humen, 523925 Dongguan, Guangdong Province, China
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Test class II / Type 2, IP66; Uc = 320 V~, In = 5 kA, I <sub>max</sub> = 10 kA, I <sub>sccr</sub> = 300 A; Up = 1300 V (L-N), Up = 1800 V (L-PE, N-PE); Maximum overcurrent protection: 20 A gG fuse
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	LSP05G277SXXXXX
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 This certificate replaces NL-40516 dated on 2016-03-30 due to technical modification.
A sample of the product was tested and found to be in conformity with	IEC 61643-11:2011 National differences: EU Group Differences 3182815.50 and 6094457.51
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands