

# INSTALLATION INSTRUCTIONS FOR SYMCOM'S MODEL 777-HVR ELECTRONIC OVERLOAD RELAY HIGH VOLTAGE CONTROL RELAY (470 VA @ 600 VAC)

**BE SURE POWER IS DISCONNECTED PRIOR TO INSTALLATION!!  
FOLLOW NATIONAL, STATE AND LOCAL CODES!  
READ THESE INSTRUCTIONS ENTIRELY BEFORE INSTALLATION.**

## CONNECTIONS

- Using the four corner tabs OR the DIN rail mounting bracket, mount the Model 777-HVR directly above or below the magnetic contactor. To use the DIN rail bracket, hook the top clip first, then apply downward pressure until the lower clip "clicks" onto the rail, then stop applying downward pressure.
- Insert the motor conductors through the round holes marked "A", "B", and "C." Terminate the conductors at the line or load side of the magnetic contactor. **Note: For motors with full load amps less than 25 Amps**, loop the conductors through the holes marked "A", "B", and "C" according to Table No. 1 below. The rectangular holes behind the holes marked "A", "B" and "C" are provided for wire looping. (see Figure No. 1).
- For motors with full load current above 90 A**, external Current Transformers must be used (see Figure No. 2). SymCom recommends that the external CT have terminals for installation convenience. When using external CTs, five passes must be made through the holes in the Model 777-HVR. Also, all CTs must be facing the same direction and all CT secondaries must be wired identically (i.e., all "+" terminal connected wires must enter loop window from the same side.
- Connect the three-phase power from the line side of the contactor to "L1", "L2" and "L3". First insert a #14 - #18 AWG wire into the top of the terminal marked L1 and tighten the screw on the front of the overload relay. Then, connect the other end of the wire to the line side of the contactor. Repeat these two steps for L2 and L3 (See Figure No. 1).
- Connect the output relay to the circuitry to be controlled (See Figure No. 1). To control a motor, connect the normally open contact in series with the magnetic coil of the motor starter as shown. To sound an alarm, connect the normally closed contact in series with the alarm (not shown).

| FullLoad Amps                                                       | # of Loops | # of Conductor s<br>through A, B and C | MUL T to Program<br>(CT ratio) |
|---------------------------------------------------------------------|------------|----------------------------------------|--------------------------------|
| 2 - 2.5                                                             | 9          | 10                                     | 10                             |
| 2.5 - 3                                                             | 8          | 9                                      | 9                              |
| 3 - 3.5                                                             | 7          | 8                                      | 8                              |
| 3.5 - 4                                                             | 6          | 7                                      | 7                              |
| 4 - 5                                                               | 5          | 6                                      | 6                              |
| 5 - 6                                                               | 4          | 5                                      | 5                              |
| 6 - 8                                                               | 3          | 4                                      | 4                              |
| 8 - 12                                                              | 2          | 3                                      | 3                              |
| 12 - 25                                                             | 1          | 2                                      | 2                              |
| 25 - 90                                                             | 0          | 1                                      | 1                              |
| ↓ EXTERNAL CT s REQUIRED . SEE WIRING DIAGRAM FOR EXTERNAL CT s . ↓ |            |                                        |                                |
| 80 - 110                                                            | 4          | 5                                      | 100 (100:5)                    |
| 110 - 160                                                           | 4          | 5                                      | 150 (150:5)                    |
| 160 - 220                                                           | 4          | 5                                      | 200 (200:5)                    |
| 220 - 320                                                           | 4          | 5                                      | 300 (300:5)                    |
| 320 - 420                                                           | 4          | 5                                      | 400 (400:5)                    |
| 400 - 520                                                           | 4          | 5                                      | 500 (500:5)                    |
| 480 - 620                                                           | 4          | 5                                      | 600 (600:5)                    |
| 600 - 800                                                           | 4          | 5                                      | 800 (800:5)                    |

**Table No. 1: Wiring Configuration Based on Motor Amps**






FIGURE NO. 1: Typical Wiring Diagram





FIGURE NO. 2: Typical wiring diagram when CTs are used.

## PROGRAMMING

1. Select the feature to program by rotating the "MODE SELECT" switch to the desired position. The "MULT" setting must be programmed before any of the current settings to ensure proper display of actual current setpoints. Therefore, SymCom recommends programming the "LV" setting first, then move clockwise through the positions to complete the process.
2. Push and hold the "RESET / PROGRAM" button.
3. Rotate the "DISPLAY / PROGRAM" adjustment to the desired setting of the feature as shown in the LED display.
4. Release the "RESET / PROGRAM" button. The Model 777-HVR is programmed when the button is released.
5. Continue steps 1-4 until all features are programmed.



**NOTE:** Some "MODE SELECT" positions are dual function such as the "#RU / ADDR" position. When the "MODE SELECT" switch is pointed at "#RU / ADDR," you may view and program "#RU" and "ADDR." To view the two settings rotate the "DISPLAY / PROGRAM" adjustment across its entire range. You will see the "#RU" setting when the "DISPLAY / PROGRAM" adjustment is between approximately 7 O'Clock and 11 O'Clock. You will see the "ADDR" setting when the "DISPLAY / PROGRAM" adjustment is between approximately 11 O'Clock and 5 O'Clock.

To program "#RU or "ADDR," follow the programming instructions above. The "#RU" setting will only be programmed when the "DISPLAY / PROGRAM" adjustment is between approximately 7 O'Clock and 11 O'Clock. Likewise, the "ADDR" setting will only be programmed when the "DISPLAY / PROGRAM" adjustment is between approximately 11 O'Clock and 5 O'Clock. "ADDR" settings will be an "A" followed by a number between 1 and 99.

## **SUGGESTED SETTINGS** (Consult the Motor Manufacturer for their recommendations.)

[Don't forget to read the programming examples on page 6.]

**LV/HV:** The recommended settings for "LV" (low voltage) and "HV" (high voltage) depend on many factors such as motor usage, motor size, environmental factors and tolerance of the motor. The motor manufacturer should be consulted for "HV" and "LV" settings. However, the NEMA MG1 standard recommends that "LV" and "HV" be set to no more than  $\pm 10\%$  of the motor's nameplate voltage. The setting can be determined by multiplying the motor's nameplate voltage by the recommended percent over and under voltage. (eg., The motor nameplate voltage is 460 V, set "LV" to  $0.9 \times 460 = 414$ , set "HV" to  $1.10 \times 460 = 506$ ) "LV" can not be set higher than "HV", so "HV" may have to be adjusted higher before the proper "LV" setting can be programmed.

**VUB-** "VUB" is the voltage unbalance trip point. The NEMA MG1 standard does not recommend operating a motor above a 1% voltage unbalance without derating the motor. Voltage unbalance is determined from the following formula:

$$\% \text{ Voltage Unbalance} = [(\text{Maximum Deviation from the Average}) / \text{Average}] \times 100\%$$

The NEMA MG1 standard also recommends against operating a motor above a 5% voltage unbalance under any circumstances. Therefore, a setting of "5" is a good place to start but SymCom recommends consulting the motor manufacturer for specific tolerances.

**Note:** A setting of "999" in this position will eliminate voltage unbalance and single phasing protection.

**MULT-** "MULT" is the multiplication factor for determining true current settings and represents the number of conductors passing through the main current windows marked "A", "B" and "C," or current transformer ratio of external CTs. The appropriate number can be determined from Table No. 1 on page 1. "MULT" must be correctly programmed in order to accurately program the current settings.

**OC-** **Represents the manufacturer's maximum service factor amperage.** The "OC" (overcurrent) setting depends on many factors such as motor usage, motor size, environmental factors and tolerance of the motor. The motor manufacturer should be consulted for "OC" settings. However, "OC" is typically between 110% and 125% of full load amperage (FLA).

**UC-** The "UC" (under current) setting is typically set to 80% of full load amperage (FLA). The overload relay with a "UC" setting of 80% of FLA will typically detect a loss of load for many pumps and motors such as a dry well condition for submersible pumps. The "UC" setting may be set to 0.00 to disable under current (loss of load) protection.

**CUB-** "CUB" is the current unbalance trip point. Most motor manufacturers recommend operating under no more than 5% current unbalance, therefore, a setting of "5" is a good place to start. However, your motor manufacturer should be contacted for exact settings.

**Note:** A setting of "999" in this position will eliminate current unbalance and single phasing protection.

**TC-** "TC" designates the trip class for overload protection. The trip class defines the trip delay when an overload is detected (see Table No. 2). Trip class is determined by the type of motor and application. Your motor manufacturer should be consulted for the proper setting. The following table shows the trip class and a general description of the applications.

**RD1-** "RD1" is the rapid cycle timer. It will engage when the motor is first powered-up or after the motor controls shut down the motor. An "RD1" setting of 20-30 seconds will generally protect the motor from rapid, successive power outages or short cycling caused by the motor controls. A setting of 0 seconds will allow the motor to start immediately after power-up or after a normal shutdown.

**RD2-** "RD2" is the restart delay after the overload relay trips on current unbalance, single phasing and overload (if "oc" is programmed in "#RF"). This delay allows the motor to cool down after experiencing the above faults. It is also known as a motor cool down timer. Your motor manufacturer should be contacted to determine this setting. Under normal circumstances, a setting of 5-10 minutes will give the motor enough time to cool down between faults.

**RD3-** "RD3" is the restart delay after an undercurrent. It is also known as a dry well recovery timer and is usually used in submersible pumping applications. The setting of "RD3" depends on the recovery time of the water well and varies widely from application to application.


**#RU-** "#RU" is the number of successive restart attempts allowed after an undercurrent fault before the overload relay requires manual reset. A setting of "0" is manual reset and a setting of "A" is continuously automatic reset.

**ADDR-** "ADDR" is the address setting for RS485 communications. Available settings are from A01 - A99. This setting is programmed on the right half of the PROGRAM/DISPLAY adjustment (see programming instruction note for explanation of dual function settings). You may ignore this setting if RS485 communications are not used.

**#RF-** "#RF" is the number of successive restart attempts allowed after a current unbalance, single phasing or overload fault. The following settings are available: "0", "1", "oc1", "2", "oc2", "3", "oc3", "4", "oc4", "A", and "ocA". A setting which includes "oc" will allow the overload relay to automatically reset after an overload fault (eg., a setting of "oc2" will allow the overload relay to reset 2 times after an overload condition before locking out if an overload condition is detected immediately after each of those two times.) A setting which does not include "oc" requires a manual reset for all overload faults. A setting of "0" is manual reset and a setting of "A" is continuously automatic.

| Trip Class | Application Description                                                                                                                                                                                                                            |
|------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 5          | Small fractional horsepower motors where acceleration times are almost instantaneous or where extremely quick trip times are required.                                                                                                             |
| 10         | (Fast Trip) Hermetic refrigerant motors, compressors, submersible pumps and general purpose motors that reach rated speed in less than 4 seconds.                                                                                                  |
| 15         | Certain specialized applications.                                                                                                                                                                                                                  |
| 20         | (Standard Trip) Most NEMA-rated general purpose motors will be protected by this setting.                                                                                                                                                          |
| 30         | (Slow Trip) Motors with long acceleration times (>10 seconds) or high inertia loads                                                                                                                                                                |
| J Prefix   | Programming any of the trip classes with the J Prefix will enable jam protection. This additional protection is enabled 1 minute after the motor starts and provides a 2 second trip time for motors exceeding 400% SFA, regardless of trip class. |

**TABLE NO. 2: Trip Class Descriptions**



**FIGURE NO. 3: Overload Trip Classes**

**UCTD-** "UCTD" is the undercurrent trip delay timer. This setting represents the maximum time that the Model 777-HVR will tolerate an under current condition. Typically, UCTD is set to 2 - 4 seconds.

**GF-** "GF" is the ground fault protection amperage threshold. This setting detects a leakage current to ground and signals an insulation breakdown in the system. The "GF" setting should be some where between 10% and 20% of the full load motor current. Short circuit protection is provided by separate branch protective devices such as circuit breakers or fuses.

Ground fault protection is a Class II ground fault protector and should not be used for personnel safety, but can be used to indicate motor degradation for maintenance purposes.

## **PROGRAMMING EXAMPLES**

**#1-** Motor To Be Protected: 3Ø, 460 Volt, 25 Hp air compressor with a full load amperage rating of 34A and maximum service factor amps of 37.4.

Use the following calculations and reasoning to determine the appropriate settings for this application.

LV-  $460 \times 0.90 = 414$

HV-  $460 \times 1.10 = 506$

VUB- Standard NEMA motor = 5

MULT - From Table No. 1 = 1

OC- Service Factor Amperage = 37.4

UC-  $FLA \times 0.80 = 34A \times 0.80 = 27.2$

CUB- Standard NEMA motor = 5

TC- General purpose motor = 20

RD1- Since this compressor takes about 10 seconds to bleed off excess pressure after a shutdown, setting RD1 = 20 will allow the compressor to unload before being restarted.

RD2- Because the motor may be hot from running in an unbalance or single phase condition, a motor cool down time of 10 minutes, RD2 = 10, should be appropriate.

RD3 / #RU- Because an undercurrent would signal a serious problem in this application (a broken shaft or belt), #RU should be set = 0 for a manual reset. Therefore, RD3 does not have any function.

#RF- Because an overload (overcurrent) fault signals a serious problem in this application (e.g., worn bearings), "oc" should not be included in the #RF setting so that a manual reset after an overload fault is required. A #RF= 1 will give the system 1 chance to recover from an unbalance or single phasing problem before manual reset is required.

UCTD- Setting UCTD = 5 will allow normal operation and not allow the motor to run too long in a failure mode.

GF- A ground fault setting of 15% of full load amps will be a significant indicator that the motor should be evaluated for repair or replacement. Therefore, GF =  $34A \times 0.15 = 5.1$ .

**#2 - Motor To Be Protected:** 3Ø, 460 Volt, 10 Hp submersible pump with a full load amperage of 14.2 A and maximum service factor amps of 16.1.

Use the following calculations and reasoning to determine the appropriate settings for this application.

|        |                                                                                                                                                                                                                                                                                                                                   |
|--------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| LV-    | $460 \times 0.90 = 414$                                                                                                                                                                                                                                                                                                           |
| HV-    | $460 \times 1.10 = 506$                                                                                                                                                                                                                                                                                                           |
| VUB-   | Manufacturer suggests 5                                                                                                                                                                                                                                                                                                           |
| MULT - | From Table No. 1, MULT = 2, 1 loop of main conductor                                                                                                                                                                                                                                                                              |
| OC-    | Service Factor Amperage = 16.1                                                                                                                                                                                                                                                                                                    |
| UC-    | $FLA \times 0.80 = 14.2 \times 0.80 = 13.4$                                                                                                                                                                                                                                                                                       |
| CUB-   | Manufacturer suggests 5                                                                                                                                                                                                                                                                                                           |
| TC-    | From Figure No. 3, for this (and most) submersible pumps, TC = 10 (fast trip)                                                                                                                                                                                                                                                     |
| RD1-   | To protect the pump from rapid cycling, RD1 = 60                                                                                                                                                                                                                                                                                  |
| RD2-   | Since the motor is small and submerged in water, the motor will generally cool down quickly. RD2=5                                                                                                                                                                                                                                |
| RD3-   | The well history shows that it will fully recover in 2 hours. RD3 = 120                                                                                                                                                                                                                                                           |
| #RU-   | In this application, we know that the well will eventually recharge itself, #RU = A.                                                                                                                                                                                                                                              |
| #RF-   | This well is known for sand to jam the impeller, therefore "oc" should be included so that the pump will attempt to automatically restart after an overloaded condition. History shows that 2 or 3 starts and stops usually clears the sand out of the impeller. #RF = oc2 or oc3.                                                |
| UCTD-  | This well may become airlocked on startup, but will usually re-prime itself in 5 seconds or less. UCTD = 10                                                                                                                                                                                                                       |
| GF-    | Because this type of failure indicates the impending failure of the motor and it may take several days to get a new pump and schedule for a driller to remove and replace the pump, GF setting of 10% of full load amperage will give the well owner enough time to prepare for pump replacement. $GF = 14.2A \times 0.10 = 1.42$ |

### **MULTI-FUNCTION SYSTEM DISPLAY**

The output display can show various system operating parameters:

- |                   |                   |
|-------------------|-------------------|
| • Average Voltage | • Average Current |
| • L1-L2 Voltage   | • L1 Current (A)  |
| • L2-L3 Voltage   | • L2 Current (B)  |
| • L3-L1 Voltage   | • L3 Current (C)  |

When the "MODE SELECT" switch is in the "RUN" position, the LED will display one of the above operating parameters. To select or change the displayed parameter, turn the "DISPLAY / PROGRAM" adjustment to the desired position as shown on its label.

The multifunction display also announces system faults such as low voltage, high voltage, single phasing, voltage unbalance, current unbalance, and reverse phasing errors. Any time the "MODE SELECT" switch is in the "RUN" position, the "RESET/PROGRAM" button may be pushed to view the last fault which occurred. The following Display Message table shows the possible messages.


## DISPLAY MESSAGE TABLE

| Displayed Message | Meaning                                                                     |
|-------------------|-----------------------------------------------------------------------------|
| oc                | Tripped on Overcurrent                                                      |
| SP                | Tripped on Current Single Phasing                                           |
| ub                | Tripped on Current Unbalance                                                |
| uc                | Tripped on Undercurrent                                                     |
| CF                | Tripped on Contactor Failure                                                |
| GrF               | Tripped on Ground Fault                                                     |
| H I               | Tripped on High Voltage                                                     |
| Lo                | Tripped on Low Voltage                                                      |
| rP                | Incoming phases have been reversed. Your motor may run backward if started. |
| oFF               | A stop command was issued from a remote source.                             |

### COMMUNICATIONS PORT / REMOTE RESET

The Model 777-HVR comes standard with a 9-pin sub-D connector for remote communications. The Model 777-HVR supports RS-485 communication standard. This standard allows up to 99 Model 777-HVRs to be controlled and monitored from a single remote personal computer. NOTE: An RS-485 module and software is required to operate the communications bus. (Refer to RS-485 Installation Instructions for more information on this subject.)

The communications port also provides connections for remote reset as shown below.



### OPERATION

Once the overload relay has been programmed, turn the "MODE SELECT" switch to the "RUN" position. The LED display will flash "RUN" alternatively with a number representing the parameter indicated by the "DISPLAY / PROGRAM" adjustment. After the period of time programmed into RD1, the output contacts will close and the value of the parameter indicated by the "DISPLAY / PROGRAM" adjustment will appear on the LED display.

If a message other than those indicated above is shown on the LED display, see the Trouble-Shooting Table on page 9 to diagnose the problem.

| PROBLEM                                                                                                                    | SOLUTION                                                                                                                                                                                                                                                                                                                                                                                                                                                     |
|----------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| The unit will not start. Display alternates "rP" with the "DISPLAY / PROGRAM" switch parameter value.                      | The voltage inputs are reverse phased. If this is the initial start up, swap any two of the leads connected to "L1", "L2", or "L3" to correct the problem. If the overload relay has been previously running, the power system has been reverse phased. Check the phase sequence of the incoming power lines. Note: "L1" must be tapped from conductor Phase A, "L2" from B, and "L3" from C for correct power factor measurements on remote communications. |
| The unit will not start. Display alternates "SP", "uB", "HI", or "Lo" with the "DISPLAY / PROGRAM" switch parameter value. | The incoming voltage is not within the limits programmed in the "VUB", "HV", and "LV" settings. Adjust the "DISPLAY / PROGRAM" switch to read the incoming line voltage values. Correct the incoming power problem and check programmed limits to verify they are correct.                                                                                                                                                                                   |
| Display alternates "SP", "uB", or "oc" with "RUN."                                                                         | The overload relay has tripped on the fault shown on the LED display and is timing down "RD2" before restarting.                                                                                                                                                                                                                                                                                                                                             |
| Display alternates "uc" with "RUN."                                                                                        | The overload relay has tripped on undercurrent and is timing down "RD3" before restarting. If undercurrent is not a normal condition for this installation, check for broken shafts, broken belts, etc.                                                                                                                                                                                                                                                      |
| Display is showing a solid "SP", "uB", or "oc."                                                                            | The unit has tripped on the fault shown and manual reset is required because of the programmed setting in "#RF". Check the system for problems that would produce the single phase, overload or current unbalance fault like a jam.                                                                                                                                                                                                                          |
| Display is showing a solid "uc."                                                                                           | The unit has tripped on undercurrent and a manual reset is required because of the setting in "#RU." Check the system for problems that would produce a loss of load like a broken belt or a pump is out of liquid.                                                                                                                                                                                                                                          |
| Display is showing a solid "CF."                                                                                           | The unit has tripped on a single phasing of the current, but was not single phased by the incoming power. Check for damaged contacts or loose wiring.                                                                                                                                                                                                                                                                                                        |
| Display is showing a solid "GrF."                                                                                          | A ground fault current greater than the programmed "GrF" value has been detected. A manual reset is required. Check the motor for insulation breakdown.                                                                                                                                                                                                                                                                                                      |

| SPECIFICATIONS                                                                    | 777-HVR                                                       |
|-----------------------------------------------------------------------------------|---------------------------------------------------------------|
| Input Voltage                                                                     | 380 - 480 VAC, 3Ø (Standard)<br>(500-600 VAC, 3Ø Available)   |
| Frequency                                                                         | 50 - 60 Hz                                                    |
| Motor Full Load Amp Range                                                         | 2 - 90 Amps, 3Ø (Direct)<br>91 - 700 Amps, 3Ø (external CT's) |
| <b>Programmable Operating Points</b>                                              | <b>Range</b>                                                  |
| LV - Low Voltage Threshold                                                        | 340V (450V*) - HV Setting                                     |
| HV - High Voltage Threshold                                                       | LV Setting - 528V (660V*)                                     |
| VUB - Voltage Unbalance Threshold                                                 | 2 - 15% or 999%                                               |
| MULT - # of Loops or CT Ratio (XXX:5)                                             | 1 - 10 Loops or 100-700 Ratio                                 |
| OC - Over Current Threshold                                                       | (20 - 100A) / MULT or 80% - 120% of CT Primary                |
| UC - Under Current Threshold                                                      | (0, 10 - 98A) / MULT or 40% - 100% of CT Primary              |
| CUB - Current Unbalance Threshold                                                 | 2 - 25% or 999%                                               |
| TC - Over Current Trip Class **                                                   | 5, J5, 10, J10, 15, J15, 20, J20, 30, J30                     |
| RD1 - Rapid Cycle Timer                                                           | 0, 2 - 500 Seconds                                            |
| RD2 - Restart Delay After All Faults Except Under Current (Motor Cool Down Timer) | 2 - 500 Minutes                                               |
| RD3 - Restart Delay After Under Current (Dry Well Recovery Timer)                 | 2 - 500 Minutes                                               |
| #RU - Number of Restarts After Under Current                                      | 0, 1, 2, 3, 4, A (Automatic)                                  |
| ADDR - RS485 Address                                                              | A01 - A99                                                     |
| #RF - Number of Restarts After All Faults Except Under Current ***                | 0, 1, oc1, 2, oc2, 3, oc3, 4, oc4, A, ocA                     |
| UCTD - Under Current Trip Delay                                                   | 2 - 60 Seconds                                                |
| GF - Ground Fault Current Threshold                                               | (3 - 20A) / MULT or OFF                                       |
| <b>Physical Specifications</b>                                                    |                                                               |
| Output Contact Rating (Pilot Duty) SPDT                                           | 470 VA @ 600 VAC                                              |
| Transient Protection (Internal)                                                   | 2500 V for 10 mSeconds                                        |
| Accuracy                                                                          |                                                               |
| Voltage                                                                           | ±1%                                                           |
| Current                                                                           | ±3% (<100 Amps Direct)                                        |
| Timing                                                                            | 5% ± 1 Second                                                 |
| Repeatability                                                                     |                                                               |
| Voltage                                                                           | ±0.5%                                                         |
| Current                                                                           | ±1% (<100 Amps Direct)                                        |
| Temperature Range                                                                 | 0 - 70 °C                                                     |
| Dimensions                                                                        | 3.0" H x 5.1" D x 3.6" W                                      |
| Power Consumption                                                                 | 5 Watts (Max.)                                                |
| Weight                                                                            | 1.2 lbs.                                                      |

- NOTES:**   \*   575 Volt Model.
- \*\*   If J Prefix is displayed in trip class setting, jam protection is enabled.
- \*\*\*   If "oc" is displayed in the #RF setting, then Over Current will be included as a normal fault and the relay will automatically restart after RD2 expires, otherwise, manual reset is required after an Over Current fault.

## Tamper Guard


- The MotorSaver can be protected from unauthorized program changes by locking the program. This procedure is outlines as follows:
1. Rotate the Mode Select switch to 'GF'.
  2. Rotate Display/Program adjustment fully clockwise.
  3. Press and hold the Reset Button. Adjust the Display/Program adjustment until 'Loc' appears in the display.
  4. Release the Reset Button.
  5. Turn Mode Select switch to 'run'.

The program is now locked, but all settings can be viewed. This procedure can be reversed by following the procedure above except step three. This step should say: Press and hold the Reset Button. Adjust the Display/Program adjustment until 'unL' appears in the display.

The GF test must be performed before installing the MotorSaver as required by UL1053 and NEC, ANSI/NFPA 70.

**Ground Fault Testing Procedure**

- 1.Disconnect power
- 2.Hook up the three line voltages to L1, L2, and L3 as required by the installation instructions.
- 3.Program the desired parameters into the unit. For test purposes, set MULT to one and GF to the minimum allowed setting.
- 4.Construct the circuit below, using an AC power supply. This circuit simulates a ground fault condition by generating a current in one of the phases. Alternate test circuits may be used. The only requirement is the current through the current transformer must be between 115% and 150% of the GF setting and pass through only one CT window.



- 5.The values of V and R will be determined by the current required to generate a GF trip condition:  $I = V_{rms}/R$ , where  $I = 115\%$  of GF setting.
- 6.Place the unit in the run position, apply three phase power and allow the N.O. contact to close.
- 7.Energize the test circuit by pushing and holding the test push-button until the unit trips (within 8.5 seconds). The display should show GrF and the N.O. contacts should be open. Release the N.O. push button.
- 8.The results of the test are to be recorded on the test form provided. The form should be kept by those in charge of the buildings electrical installation in order to be available to the authority having jurisdiction.
- 9.Confirm programmed parameters and proceed with installation instructions.

**Ground Fault Test Results\***

| <u>Date</u> | <u>Performed by</u> | <u>Results</u> | <u>Location</u> |
|-------------|---------------------|----------------|-----------------|
|-------------|---------------------|----------------|-----------------|

\*form should be retained by buildings electrical foreman

SymCom Warrants its microprocessor based products against defects in material or workmanship for a period of five (5) years from the date of manufacture. All other products manufactured by SymCom shall be warranted against defects in material and workmanship for a period of two (2) years from the date of manufacture. For complete information on warranty, liability, terms, returns, and cancellations, please refer to the SymCom Terms and Conditions of Sale document.

